



H.B. Fuller

A.B.N: 37 003 638 435 ACN: 003 638 435
H.B. Fuller Company Australia Pty Ltd
PO Box 4202, Dandenong Sth VIC 3175
PH: 613 9797 6222 FAX: 613 9797 6299

13th November 2017

RE: VOC of HB Fuller product Fulaflex 550PU LM.

The VOC of the following product has been tested in accordance with the California South Coast air quality management rule 1168 and the results are as follows:

Product Name	VOC (g/L)
Fulaflex 550PU LM	90g/L

The details of the management rule including method of testing can be viewed at the following website:

www.arb.ca.gov/DRDB/SC/CURHTML/R1168.PDF

Yours sincerely,

Kris Bogos

Chemist
H.B. Fuller Company Australia Pty Ltd